

DEPARTMENT OF THE ARMY
Omaha District, Corps of Engineers
106 South 15th Street
Omaha, Nebraska 68102-1618

:NOTICE: Failure to acknowledge : Solicitation No. W9128F 04 B 0017
:all amendments may cause rejec- :
:tion of the bid. See FAR : Date of Issue: 29 Jul 2004
:52.214-3 of Section 00100 : Date of Opening: 30 Aug 2004

Amendment No. 0004
26 August 2004

SUBJECT: Amendment No. 0004 to Specifications and Drawings for Construction of
Camp Ashland Flood Protection Project, Platte River, NE
Solicitation No. W9128F 04 B 0017.

TO: Prospective Bidders and Others Concerned

1. The specifications and drawings for subject project are hereby modified as follows (revise all specification indices, attachment lists, and drawing indices accordingly).

a. Specifications. (Descriptive Changes.)

(1) Section 01550:

a. Page 6, paragraph 2.2, delete the last sentence of this paragraph ("For information...place quantity.") and substitute the following new text:

"For information purposes, the quantity shown on the bid sheet represents the compacted in-place quantity. Additional material will have to be excavated from the borrow area to compensate for shrinkage during compaction and other losses. A shrinkage factor of 30% can be used to estimate the volume of needed borrow material."

b. Page 6, paragraph 3.2, delete the last sentence of this paragraph ("For information...place quantity.") and substitute the following new text:

"For information purposes, the quantity shown on the bid sheet represents the compacted in-place quantity. Additional material will have to be excavated from the borrow area to compensate for shrinkage during compaction and other losses. A shrinkage factor of 20% can be used to estimate the volume of needed borrow material."

(2) Section 02331a, page 22, paragraph 3.14.2, in sentence "The lift shall be...axis of the levee", delete the phrase "50-ton".

(3) Section 02731A, page 5, paragraph 3.7, delete the portion of the sentence reading "with each tire...150 psi." and substitute the following new text:

". The tires shall be of such size and ply as to be capable of being operated at tire pressures between 80 and 100 psi with a 4,000 pound or greater wheel load."

2. This amendment is a part of the bidding papers and its receipt shall be acknowledged on the Standard Form 1442. All other conditions and requirements

of the specifications remain unchanged. If the bids have been mailed prior to receiving this amendment, you will notify the office where bids are opened, in the specified manner, immediately of its receipt and of any changes in your bid occasioned thereby.

a. Hand-Carried Bids shall be delivered to the U.S. Army Corps of Engineers, Omaha District, Contracting Division (Room 301), 106 South 15th Street, Omaha, Nebraska 68102-1618.

b. Mailed Bids shall be addressed as noted in Item 8 on Page 00010-1 of Standard Form 1442.

3. Bids will be received until 2:00 p.m., local time at place of bid opening, 30 Aug 2004.

U.S. Army Engineer District, Omaha
Corps of Engineers
106 South 15th Street
Omaha, Nebraska 68102-1618

26 Aug 2004
JDW/4529